



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE FOR OCCUPANCY



From
The Director General
State Disaster Response and Fire Services,
Telangana, Hyderabad.

To,
MS NOVA EDUCATIONAL SOCIETY,
H.No. 7-1-209/1/2/3,
Muttam setti Towers,
Beside Satyam Theatre road,
Ameerpet ,
Hyderabad.,

Ack. No.419300002021 Dated:29/10/2021

Sir,

Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –
Issue of No Objection Certificate for Occupancy to the Multi storeyed Building of SCHOOL BUILDING,SY.NO: 310,311/P,312 & 315, SITUATED AT JAFFERGUDA H/O.BATASINGARAM VILLAGE , ABDULLAPURMET MANDAL, RANGA.REDDY.DIST, T.S . /- Batasingaram/Hayathnagar/Rangareddy , Hyderabad – Regarding.



Ref:

1. Acknowledgement No419300002021
2. This Office Provisional NOC Ack/RC No.ACK No.312680002019 dt.24/09/2020
3. Multi-Storeyed Building Inspection Committee Report,, Hyderabad Ack. No. 419300002021, dt. 29/10/2021

The Multi Storeyed Building Inspection committee, vide reference cited (3) has inspected the Multi Storeyed Building of SCHOOL BUILDING,SY.NO: 310,311/P,312 & 315, SITUATED AT JAFFERGUDA H/O.BATASINGARAM VILLAGE , ABDULLAPURMET MANDAL, RANGA.REDDY.DIST, T.S . /- Batasingaram/Hayathnagar/Rangareddy on 29/10/2021 and submitted the following report.

2) The builder was issued Provisional No Objection certificate vide reference cited (2) for construction of Multi Storeyed Building 1 Ground, 4 Floors, with for EDUCATIONAL B-1 Schools up to senior secondary level. Now the builder has constructed the Multi Storeyed Building with 1 Ground, 4 Floors, with a height of 18.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy and requested for No Objection Certificate for Occupancy.

3) Open Spaces: The builder provided the following open spaces all around the building.

Sl.No	Side	Open space Required as per Provisional No Objection Certificate	Open space Provided
a 1	North	7.00	7.00
2	South	7.00	7.00
3	East	7.00	7.00
4	West	7.00	7.00

This is not stepped type building.

b Sl. No	Gate Width As per NBC 2016	Required	Provided
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	4.50	6
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	4.50	6.00

6. Travel Distance

4	This No objection Certificate for occupancy is valid for five year from the date of issue of this letter.	months. Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	101. Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.
---	---	---	---

14. Additional Fire Safety Measures Recommended by the Department:
0

This No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
Director General of State Disaster
Response & Fire Services
Telangana, Hyderabad

- Copies to:
i) The Management
ii) Multistoried Building Inspection Committee

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"